

Kansas Department of Health and Environment  
Proposed New Regulations

Article 15a. Primary Drinking Water Regulations

MAXIMUM CONTAMINANT LEVELS AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS

28-15a-60. Effective dates for maximum contaminant levels and maximum residual disinfectant levels. The provisions of 40 CFR 141.60, as in effect on July 1, 2003, are hereby adopted by reference. (Authorized by and implementing K.S.A. 65-171m; effective P-\_\_\_\_\_.)

Kansas Department of Health and Environment  
Proposed New Regulations

Article 15a. Primary Drinking Water Regulations

MAXIMUM CONTAMINANT LEVELS AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS

28-15a-61. Maximum contaminant levels for organic contaminants. The provisions of 40 CFR 141.61, as in effect on July 1, 2003, are hereby adopted by reference. (Authorized by and implementing K.S.A. 65-171m; effective P-\_\_\_\_\_.)

Kansas Department of Health and Environment  
Proposed New Regulations

Article 15a. Primary Drinking Water Regulations

MAXIMUM CONTAMINANT LEVELS AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS

28-15a-62. Maximum contaminant levels for inorganic contaminants. The provisions of 40 CFR 141.62, as in effect on July 1, 2003, are hereby adopted by reference with the addition of the following text:

“(d) The maximum contaminant level for arsenic shall apply only to community water systems. The analyses and determination of compliance with the 0.05 milligrams per liter maximum contaminant level for arsenic shall conform to the requirements of K.A.R. 28-15a-23.

“(e) The maximum contaminant level for arsenic shall be 0.05 milligrams per liter for community water systems until January 23, 2006.” (Authorized by and implementing K.S.A. 65-171m; effective P-\_\_\_\_\_.)

Kansas Department of Health and Environment  
Proposed New Regulations

Article 15a. Primary Drinking Water Regulations

MAXIMUM CONTAMINANT LEVELS AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS

28-15a-63. Maximum contaminant levels for microbiological contaminants. The provisions of 40 CFR 141.63, as in effect on July 1, 2003, are hereby adopted by reference. (Authorized by and implementing K.S.A. 65-171m; effective P-\_\_\_\_\_.)

Kansas Department of Health and Environment  
Proposed New Regulations

Article 15a. Primary Drinking Water Regulations

MAXIMUM CONTAMINANT LEVELS AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS

28-15a-64. Maximum contaminant levels for disinfection byproducts. The provisions of 40 CFR 141.64, as in effect on July 1, 2003, are hereby adopted by reference. (Authorized by and implementing K.S.A. 65-171m; effective P-\_\_\_\_\_.)

Kansas Department of Health and Environment  
Proposed New Regulations

Article 15a. Primary Drinking Water Regulations

MAXIMUM CONTAMINANT LEVELS AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS

28-15a-65. Maximum residual disinfectant levels. The provisions of 40 CFR 141.65, as in effect on July 1, 2003, are hereby adopted by reference. (Authorized by and implementing K.S.A. 65-171m; effective P-\_\_\_\_\_.)

Kansas Department of Health and Environment  
Proposed New Regulations

Article 15a. Primary Drinking Water Regulations

MAXIMUM CONTAMINANT LEVELS AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS

28-15a-66. Maximum contaminant levels for radionuclides. The provisions of 40 CFR 141.66, as in effect on July 1, 2003, are hereby adopted by reference. (Authorized by and implementing K.S.A. 65-171m; effective P-\_\_\_\_\_.)